

Low Profile E-Stop Switches

with Ø 16mm Bodies

Shortest Behind Panel Depth in Class: 13.6mm

FF01 Series Emergency Stop Switches

Twist or Pull Release

NKK is pleased to announce a new series: the FF01 Emergency Stop Switches with a 16mm diameter body and the shortest behind panel depth in its class of 13.6mm. The compact low profile contributes to flexible panel design and features 25 or 30mm diameter actuators with optional directional arrows. Offered in single or double pole models, the E-stop pushbuttons are reset by pulling and/or twisting methods. In addition to IP65 rating at the front panel, they are UL, C-UL, CE and TÜV certified. NKK's innovative sliding latch mechanism maintains the OFF state of the contacts, assuring unparalleled safety and reliability. Protective guard and nameplates are available.

Part Number	Pole	Switch Description	Actuator Size	Actuator Legend
FF0116BACAEA01		Resistive Load: 0.5A @ 24V DC Gold Contacts & Solder Lug Terminals	25.0mm	Arrows
FF0116BACEEA01	Single			25.0mm
FF0116BBCAEA01	Pole	100,000 Operations Minimum Total Travel: .177" (4.5mm)	30.0mm	Arrows
FF0116BBCEEA01]	Operating Temperature: -25°C ~ +60°C	30.0mm	No Legend
FF0126BACAEA01	Double Pole	Resistive Load: 0.5A @ 24V DC Gold Contacts & Solder Lug Terminals 100,000 Operations Minimum Total Travel: .177" (4.5mm)	25.0mm	Arrows
FF0126BACEEA01			25.0mm	No Legend
FF0126BBCAEA01			30.0mm	Arrows
FF0126BBCEEA01		Operating Temperature: -25°C ~ +60°C	30.0mm	No Legend

		Accessories		
		Part Number	Image	Description
		AT119 Socket Wrench		Brass with Nickel Plating; For Switch Installation
FF0116BACAEA01	FF0116BACEEA01	AT220 Protective Guard		Glass Fiber Reinforced Polyamide; O-ring Included
		AT221 Nameplate No Legend	0	Glass Fiber Reinforced Polyamide; O-ring Included
FF0126BBCAEA01	FF0126BBCEEA01	AT222 Nameplate With Legend	STOR STOR	Glass Fiber Reinforced Polyamide; O-ring Included

Series FF01

General Specifications

Electrical Capacity

Resistive Load: 0.5A @ 24V DC

Other Ratings

Rated Insulation Voltage:	36V DC
Impulse Withstand Voltage:	2.5kV
Contact Resistance:	50 milliohms maximum
Insulation Resistance:	100 megohms minimum @ 500V DC
Mechanical Life:	100,000 operations minimum
Electrical Life:	100,000 operations minimum
Operating Force:	Push to lock 10.8N; Pull to reset 8.5N; Turn to reset 0.13N m
Minimum Direct Operating Force:	15N
Short Circuit Protection:	gG10A
Conditional Short Circuit Current:	1000A
Total Travel:	.177″ (4.5mm)
Operation Frequency:	10 times per minute
Overvoltage Category:	

Materials & Finishes

Actuator:	Glass fiber reinforced polyester (PBT)
Housing:	Glass fiber reinforced polyamide
Movable Contacts:	Silver alloy copper with gold plating
Stationary Contacts:	Silver alloy copper with gold plating
Terminals:	Brass with tin plating

Environmental Data

Operating Temperature Range:	–25°C through +60°C (–13°F through +140°F)
Storage Temperature Range:	-45°C through +80°C (-49°F through +176°F)
Humidity:	90 ~ 95% humidity for 240 hours @ +40°C (+104°F)
Vibration:	10 ~ 500Hz, amplitude 0.35mm. Acceleration 50m/s ²
Shock:	Durability: 1,000m/s ² ; Malfunction: 150m/s ²
Pollution Degree:	3
Sealing:	Meets IP65 of IEC 60529 Standards at front panel

Installation

Mounting Torque: Soldering Time & Temperature: 785mN•m Manual Soldering: 390°C maximum for 4 seconds maximum, 2 cycles

Standards & Certifications




EN 60947-5-1, EN 60947-5-5 **CE**





2

Series FF01



30.0mm (1.181")

Material: Glass fiber reinforced PBT Actuators are not available separately.

Finish: Matte

No Legend

Emergency Stop Switches

HOUSING



Housing available in yellow with a matte finish.


CONTACT MATERIALS, RATINGS & TERMINALS

A01

Gold over Silver

Power Level 0.5A @ 24V DC Solder Lug Terminals

(16.2)^{+0.2} .638




PANEL THICKNESS & CUTOUT

Panel Thickness

Recommended Panel Thickness: .031" ~ .177" (0.8mm ~ 4.5mm)


OPTIONAL ACCESSORIES



One o-ring provided with each protective guard

Materials & Colors:

Guard: Glass fiber reinforced polyamide O-ring: Chloroprene rubber Guard: Yellow O-ring: Black AT221 Nameplate without Legend




One o-ring provided with each nameplate

Materials & Colors:

Nameplate: Glass fiber reinforced polyamide O-ring: Chloroprene rubber

Nameplate: Yellow O-ring: Black



→ | | + .067 ^{+0.2}

(17.9)^{+0.2}



One o-ring provided with each nameplate


Materials & Colors:

Nameplate: Glass fiber reinforced polyamide O-ring: Chloroprene rubber Nameplate: Yellow with black letters O-ring: Black

Panel Thickness & Cutout for Protective Guard or Nameplates

Recommended Panel Thickness:

.020" ~ .118" (0.5mm ~ 3.0mm)



AT119 Socket Wrench

Material: Brass with nickel plating Use to tighten switch nut in installation




5

Series FF01


TYPICAL SWITCH DIMENSIONS

25.0mm Cap With or Without Actuator Legend • SPST



FF0116BACAEA01


25.0mm Cap With or Without Actuator Legend • DPST





FF0126BACEEA01

30.0mm Cap With or Without Actuator Legend • SPST











FF0116BBCAEA01

30.0mm Cap With or Without Actuator Legend • DPST




FF0126BBCEEA01





M16 P1





6

SAFETY PRECAUTIONS & INSTALLATION INSTRUCTIONS

Installation of Switch & AT220 Protective Guard

* The protective guard complies with international standards. Read carefully to ensure the product will be used properly.

Safety Precautions

- The protective guard is made exclusively for use with NKK's FF01 Series and should not be used with other types of products.
- Read the FF01 Series Instruction Manual before switch installation, cable connection, operation, maintenance or inspection.
- Confirm power is off before installation, cable connection, maintenance, etc.
- When installing product on other equipment, be sure usage is in compliance with standards and regulations of your country or region, as required for your system, equipment or facility.


Installation of Switch & Guard into Panel


- 1. Remove the nut from the switch body.
- 2. Insert the switch body into the protective guard from the front of the guard, aligning notch on the o-ring with the anti-rotation tab on the switch body. Align the anti-rotation tab on the switch body with the keyway on the guard.
- 3. Align the anti-rotation tab on the back of guard with the antirotation keyway on the panel.
- 4. Using the AT119 Socket Wrench, tighten the nut from the back of the panel (recommended torque 785mN•m).

Installation Height

- To install the switch with the protective guard onto semiconductor manufacturing equipment, the mounting height range should be 33.0 inches to 64.5 inches (838mm to 1,638mm). The maximum horizontal reach should be between 7.0 inches and 10.0 inches (178mm to 254mm) (SEMI S8).
- The switch must be installed within 118.0 inches (3.0 meters) from the working position (SEMI S2).
- To install the switch with the protective guard on equipment such as machine tools or processing equipment, the recommended height range is between 23.5 and 67.0 inches (600mm and 1,700mm) from the floor or platform level (ISO 13850).
 Note: To confirm that the switch and protective guard mounted on a device are ISO compliant, see requirements of ISO 13850.
- * To comply with the SEMI Standard, it is necessary that "EMO" (Emergency Off) is printed on the switch or on the inside of the protective guard. Contact NKK Switches for more information.

Height		Horizontal Reach (Maximum)	
Inches	Millimeters	Inches	Millimeters
64.5	1,638	10.0	254
60.0	1,524	14.5	368
56.0	1,422	17.0	432
52.0	1,321	18.5	470
48.0	1,219	19.0	483
44.0	1,118	18.5	470
40.0	1,016	15.5	394
36.0	914	11.5	292
33.0	838	7.0	178





The table and illustration show the mounting range for the assembled emergency stop switch and protective guard. The height and horizontal reach are determined according to SEMI S8.



SAFETY PRECAUTIONS & INSTALLATION INSTRUCTIONS

Installation of Switch

Safety Precautions


- Read the FF01 Series Instruction Manual before switch installation, cable connection, operation, maintenance or inspection.
- Confirm power is off before installation, cable connection, maintenance, etc.
- When installing product on other equipment, be sure usage is in compliance with standards and regulations of your country or region, as required for your system, equipment or facility.
- Use the switch at the voltage and current recommendations in the specifications. Exceeding these may cause overheating.
- Use wiring with the appropriate rating.
- Follow recommended panel cutout dimensions and mounting instructions or switch may not operate properly.
- Remove dirt and dust from switch mounting surface of the panel before beginning installation.
- Do not disassemble the product, as it may cause malfunction, electric shock or fire.
- Operate switch by hand only; do not operate using foot, tool or other object.
- Bouncing may occur during a reset operation (pull or turn to reset). If switch-mounted equipment is subjected to shock or vibration, it may cause chattering. Take appropriate measures to prevent bouncing and chattering on the equipment side.
- Do not drop the switch or apply excessive shock or vibration. Deformation or damage may cause malfunction or performance degradation.
- After inserting the lead wire into the terminal hole, use a soldering iron to ensure a secure connection.
- If soldering is executed with terminals facing up, avoid allowing the flux to enter the interior of the switch.
- Soldering temperature is 390°C maximum within four seconds.

Usage Environment

- This product is designed for indoor use.
- Avoid using the switch in environments where there is frequent splashing water.
- If the switch becomes wet, wipe off with a dry cloth. Using a switch exposed to water may result in water entering inside. If the water freezes inside the switch, it may not function properly.
- In an environment where dust and dirt may accumulate, remove deposits around switch before use. When necessary, a cloth dampened with a small amount of neutral detergent may be used. Follow using a dry cloth.

Installation of Switch into Panel

- 1. Remove the nut from the switch body.
- 2. Insert the switch body into the panel, aligning notch on the o-ring with the anti-rotation tab on the switch body. Align the anti-rotation tab on the switch body with the anti-rotation keyway on the panel.
- 3. Using the AT119 Socket Wrench, tighten the nut from back of panel (recommended torque 785mN•m).



Effective Date May 2020



